

This is a preview of "NSF/ANSI 42-2018". Click here to purchase the full version from the ANSI store.



*NSF International Standard /  
American National Standard*

## NSF/ANSI 42 - 2018

### Drinking Water Treatment Units - Aesthetic Effects



*NSF International, an independent, not-for-profit, nongovernmental organization, is dedicated to being the leading global provider of public health and safety based risk management solutions while serving the interests of all stakeholders.*

This Standard is subject to revision.  
Contact NSF to confirm this revision is current.

Users of this Standard may request clarifications and interpretations, or propose revisions by contacting:

Chair, Joint Committee on Drinking Water Treatment Units  
c/o NSF International  
789 North Dixboro Road, PO Box 130140  
Ann Arbor, Michigan 48113-0140 USA  
Phone: (734) 769-8010 Telex: 753215 NSF INTL  
Fax: (734) 769-0109  
E-mail: [info@nsf.org](mailto:info@nsf.org)  
Web: [www.nsf.org](http://www.nsf.org)

**NSF/ANSI 42 – 2018**

NSF International Standard /  
American National Standard  
for Drinking Water Treatment Units –  
**Drinking Water Treatment Units –  
Aesthetic Effects**

Standard Developer  
**NSF International**

**Designated as an ANSI Standard**  
July 31, 2018  
**American National Standards Institute**

Prepared by  
**The NSF Joint Committee on Drinking Water Treatment Units**

Recommended for adoption by  
**The NSF Council of Public Health Consultants**

Adopted by  
**NSF International**  
March 1973

Revised June 1982  
Revised September 1997  
Revised July 2000  
Revised January 2002  
Editorial revision November 2003  
Editorial revision June 2005  
Addendum March 2008  
Revised February 2012  
Revised January 2015  
Revised November 2017

Revised June 1988  
Revised November 1998  
Revised November 2000  
Addendum 1.0 June 2002  
Addendum 1.0 August 2004  
Revised July 2007  
Revised August 2009  
Revised December 2012  
Revised October 2015  
Revised November 2018

Revised September 1996  
Revised September 1999  
Revised January 2001  
Addendum 2.0 October 2002  
Revised April 2005  
Revised October 2007  
Revised February 2011  
Revised December 2013  
Revised February 2017

Published by  
**NSF International**  
PO Box 130140, Ann Arbor, Michigan 48113-0140, USA

For ordering copies or for making inquiries with regard to this Standard, please reference the designation "NSF/ANSI 42 – 2018."

Copyright 2018 NSF International

Previous editions © 2017, 2016, 2015, 2014, 2013, 2012, 2011, 2009, 2008, 2007, 2005, 2004, 2002, 2001, 2000, 1999, 1998, 1997, 1996, 1988, 1982, 1973

Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from NSF International.

Printed in the United States of America.

## Disclaimers<sup>1</sup>

NSF International (NSF), in performing its functions in accordance with its objectives, does not assume or undertake to discharge any responsibility of the manufacturer or any other party. The opinions and findings of NSF represent its professional judgment. NSF shall not be responsible to anyone for the use of or reliance upon this Standard by anyone. NSF shall not incur any obligation or liability for damages, including consequential damages, arising out of or in connection with the use, interpretation of, or reliance upon this Standard.

NSF Standards provide basic criteria to promote sanitation and protection of the public health. Provisions for mechanical and electrical safety have not been included in this Standard because governmental agencies or other national standards setting organizations provide safety requirements.

Participation in NSF Standards development activities by regulatory agency representatives (federal, local, state) shall not constitute their agency's endorsement of NSF or any of its Standards.

Preference is given to the use of performance criteria measurable by examination or testing in NSF Standards development when such performance criteria may reasonably be used in lieu of design, materials, or construction criteria.

The illustrations, if provided, are intended to assist in understanding their adjacent standard requirements. However, the illustrations may not include all requirements for a specific product or unit, nor do they show the only method of fabricating such arrangements. Such partial drawings shall not be used to justify improper or incomplete design and construction.

Unless otherwise referenced, the annexes are not considered an integral part of NSF Standards. The annexes are provided as general guidelines to the manufacturer, regulatory agency, user, or certifying organization.

---

<sup>1</sup> The information contained in this Disclaimer is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. Therefore, this Disclaimer may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

This page is intentionally left blank.

## Contents

1	General .....	1
1.1	Purpose.....	1
1.2	Scope .....	1
1.3	Alternate materials, designs, and construction.....	1
1.4	Chemical and mechanical reduction performance claims .....	1
1.5	Minimum requirements .....	2
1.6	Treatment train.....	2
2	Normative references .....	2
3	Definitions .....	3
4	Materials .....	3
4.1	Materials in contact with drinking water .....	3
4.2	Materials evaluation .....	4
4.3	Gas chromatography / mass spectroscopy (GC/MS) analysis .....	6
4.4	Materials in contact with the user's mouth.....	8
5	Structural performance .....	12
5.1	Structural integrity .....	12
5.2	Acceptance .....	12
5.3	Working pressure.....	13
5.4	Structural integrity test methods .....	13
6	Minimum performance requirements.....	19
6.1	Elements .....	19
6.2	Waste connections.....	19
6.3	Product water dispensing outlets.....	19
6.4	Hazards.....	19
6.5	Operation temperature.....	19
6.6	Rated service flow.....	19
6.7	POE rated pressure drop .....	20
6.8	Minimum service flow.....	20
6.9	Active agents and additives .....	20
7	Elective performance claims – Test methods.....	21
7.1	General requirements .....	21
7.2	Bacteriological performance .....	23
7.3	Chemical reduction testing .....	25
7.4	Mechanical reduction testing .....	47
7.5	Scale control testing.....	50
8	Instruction and information .....	52
8.1	Installation, operation, and maintenance instruction .....	52
8.2	Data plate.....	53
8.3	Replacement components .....	55
8.4	Performance data sheet .....	56
Annex A	Key elements of a certification program for drinking water treatment systems and components .....	59
A.1	Marking the product .....	59
A.2	Listing certified companies .....	59
A.3	Annual audits .....	59
A.4	Testing .....	59

A.5	Toxicological evaluation of materials formulations .....	60
A.6	Corrective action .....	60
A.7	Enforcement.....	60
A.8	Administrative review .....	60
A.9	Appeals .....	60
A.10	Complaints .....	60
A.11	Advertising .....	61
A.12	Records.....	61
A.13	Public notice.....	61
A.14	Confidentiality .....	61
Annex B	Procedure for the analysis of monochloramine by high performance liquid chromatography (HPLC) .....	63
B.1	Summary of method.....	63
B.2	Equipment and materials .....	63
B.3	Reagents and consumable materials .....	63
B.4	Safety .....	65
B.5	Procedure .....	66
B.6	Data analysis .....	66
B.7	Quality control .....	66
B.8	References.....	68
Annex C	.....	69
Annex D	Test method for evaluating mouth drawn water treatment units .....	71
D.1	Scope and purpose.....	71
D.2	Method .....	71
D.3	Sampling .....	71
Annex E	Test method for evaluating squeeze bottle drinking water treatment units .....	75
E.1	Scope and purpose.....	75
E.2	Method – Mechanical gripper apparatus .....	75
E.3	Alternate method – Pressurized bottle.....	76
E.4	Sampling .....	76
Annex F	Methods and procedures to minimize premature filter plugging.....	79
F.1	Mechanical filtration component of tested system.....	79
F.2	Mechanical filtration of waters .....	79
F.3	Disinfection and cleaning of test apparatus.....	79
F.4	Antimicrobial treatment .....	80
F.5	Methanol used as carrier solvent.....	80
F.6	Operational cycle .....	80
Annex G	Evaluation methods for systems with multiple technologies – Treatment train .....	81
G.1	Requirements for the evaluation of a system containing multiple, sequential treatment technologies.....	81
G.2	Example application of treatment train option B .....	82
G.3	Example application of treatment train option C .....	83
Interpretation Annex	.....	85



## **Foreword<sup>2</sup>**

The purpose of this Standard is to establish minimum requirements for materials, design, construction, and performance of drinking water treatment units that are designed to reduce specific aesthetic-related contaminants in public or private water supplies. This Standard specifies the minimum product literature and labeling information that a manufacturer must supply to authorized representatives and system owners. Lastly, the Standard provides minimum service related obligations that the manufacturer must extend to system owners.

This edition of the Standard contains the following revisions:

### **Issue 97**

This revision addresses inconsistent language across the scopes of the DWTU Standards and adds clarifying language on systems that include components or functions covered under other NSF Standards.

### **Issue 99**

This revision adds clarification to the product literature requirements under Section 8.3 for replacement components.

This Standard was developed by the NSF Joint Committee on Drinking Water Treatment Units using the consensus process described by the American National Standards Institute.

Suggestions for improvement of this Standard are welcome. This Standard is maintained on a Continuous Maintenance schedule and can be opened for comment at any time. Comments should be sent to Chair, Joint Committee on Drinking Water Treatment Units at [standards@nsf.org](mailto:standards@nsf.org), or c/o NSF International, Standards Department, PO Box 130140, Ann Arbor, Michigan 48113-0140, USA.

---

<sup>2</sup> The information contained in this Foreword is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. Therefore, this Foreword may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

This page is intentionally left blank.

# NSF/ANSI Standard for Drinking Water Treatment Units – Drinking Water Treatment Units – Aesthetic Effects

## 1 General

### 1.1 Purpose

It is the purpose of this Standard to establish minimum requirements for materials, design and construction, and performance of drinking water treatment systems that are designed to reduce specific aesthetic related (nonhealth effects) contaminants in public or private water supplies. This Standard also specifies the minimum product literature and labeling information that a manufacturer shall supply to authorized representatives and system owners as well as the minimum service related obligations that the manufacturer shall extend to system owners.

### 1.2 Scope

The point-of-use (POU) and point-of-entry (POE) systems addressed by this Standard are designed to be used for the reduction of specific substances that may be present in drinking water (public or private) considered to be microbiologically safe and of known quality. Systems covered under this Standard are intended to address one or more of the following: reduce substances affecting the aesthetic quality of the water, add chemicals for scale control, or limit microbial growth in the system (bacteriostatic). Substances may be soluble or particulate in nature. It is recognized that a system may be effective in controlling one or more of these substances but is not required to control all. Systems with manufacturer claims that include components or functions covered under other NSF or NSF/ANSI Standards or Criteria shall conform to the applicable requirements therein. Filter systems covered by this Standard are not intended to be used with drinking water that is microbiologically unsafe or of unknown quality without adequate disinfection before or after the system.

NOTE — Systems that are compliant with NSF/ANSI 55 Class A or other standards that cover technologies to treat microbiologically unsafe water (e.g., US EPA *Guide Standard and Protocol for Testing Microbiological Water Purifiers* or NSF P231) are examples of demonstrating adequate disinfection before or after the system.

### 1.3 Alternate materials, designs, and construction

While specific materials, designs, and construction may be stipulated in this Standard, systems that incorporate alternate materials, designs, and construction may be acceptable when it is verified that such systems meet the applicable requirements stated herein.

### 1.4 Chemical and mechanical reduction performance claims

**1.4.1** All NSF/ANSI 42 performance claims shall be verified and substantiated by test data generated under the requirements of NSF/ANSI 42.

**1.4.2** When performance claims are made for substances not specifically addressed in the scope of this Standard or for substances not specifically addressed but falling under the scope of NSF/ANSI 42, such claims shall be identified as not specifically addressed in the Standard.