

This is a preview of "NSF/ANSI 55-2019". Click here to purchase the full version from the ANSI store.



*NSF International Standard /
American National Standard*

NSF/ANSI 55 - 2019

Ultraviolet Microbiological Water Treatment Systems



NSF International, an independent, not-for-profit, nongovernmental organization, is dedicated to being the leading global provider of public health and safety-based risk management solutions while serving the interests of all stakeholders.

This Standard is subject to revision.
Contact NSF to confirm this revision is current.

Users of this Standard may request clarifications and interpretations, or propose revisions by contacting:

Chair, Joint Committee on Drinking Water Treatment Units
c/o NSF International
789 North Dixboro Road, PO Box 130140
Ann Arbor, Michigan 48113-0140 USA
Phone: (734) 769-8010 Telex: 753215 NSF INTL
Fax: (734) 769-0109
Email: info@nsf.org
Web: www.nsf.org

NSF/ANSI 55 – 2019

NSF International Standard /
American National Standard
for Drinking Water Treatment Units –
Ultraviolet Microbiological Water Treatment Systems

Standard Developer
NSF International

Designated as an ANSI Standard
July 29, 2019
American National Standards Institute

Prepared by
The NSF Joint Committee on Drinking Water Treatment Units

Recommended for adoption by
The NSF Council of Public Health Consultants

Adopted by
NSF International
May 1991

Revised January 2000
Addendum, February 2004
Revised August 2009
Revised January 2015
Revised November 2018

Revised January 2002
Revised October 2004
Revised August 2012
Revised December 2016
Revised September 2019

Addendum, June 2002
Revised October 2007
Revised December 2013
Revised November 2017

Published by
NSF International
PO Box 130140, Ann Arbor, Michigan 48113-0140, USA

For ordering copies or for making inquiries with regard to this Standard, please reference the designation "NSF/ANSI 55 – 2019".

Copyright 2019 NSF International

Previous editions © 2019, 2018, 2017, 2015, 2014, 2013, 2012, 2009, 2007, 2004, 2002, 2000, 1991

Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from NSF International.

Printed in the United States of America.

Disclaimers¹

NSF International (NSF), in performing its functions in accordance with its objectives, does not assume or undertake to discharge any responsibility of the manufacturer or any other party. The opinions and findings of NSF represent its professional judgment. NSF shall not be responsible to anyone for the use of or reliance upon this Standard by anyone. NSF shall not incur any obligation or liability for damages, including consequential damages, arising out of or in connection with the use, interpretation of, or reliance upon this Standard. It is the responsibility of the user of this standard to judge the suitability of the ANS for the user's purpose.

NSF Standards provide basic criteria to promote sanitation and protection of public health and the environment. Provisions for mechanical and electrical safety have not been included in this Standard because governmental agencies or other national standards-setting organizations provide safety requirements.

Participation in NSF Standards development activities by regulatory agency representatives (federal, local, state) shall not constitute their agency's endorsement of NSF or any of its Standards.

Preference is given to the use of performance criteria measurable by examination or testing in NSF Standards development when such performance criteria may reasonably be used in lieu of design, materials, or construction criteria.

The illustrations, if provided, are intended to assist in understanding their adjacent standard requirements. However, the illustrations may not include all requirements for a specific product or unit, nor do they show the only method of fabricating such arrangements. Such partial drawings shall not be used to justify improper or incomplete design and construction.

At the time of this publication, examples of programs and processes were provided for general guidance. This information is given for the convenience of users of this standard and does not constitute an endorsement by NSF International. Equivalent programs and processes may be used.

Unless otherwise referenced, the annexes are not considered an integral part of NSF Standards. The annexes are provided as general guidelines to the manufacturer, regulatory agency, user, or certifying organization.

¹ The information contained in this Disclaimer is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. Therefore, this Disclaimer may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

This page is intentionally left blank.

Contents

1	General	1
1.1	Purpose	1
1.2	Scope	1
1.3	Variance from minimum requirements	2
1.4	Alternate materials	2
2	Normative references	2
3	Definitions	3
4	Materials	3
4.1	Materials in contact with drinking water	3
4.2	Materials evaluation	4
4.3	Gas chromatography / mass spectroscopy (GC/MS) analysis	5
5	Structural performance	12
5.1	Structural integrity	12
6	Minimum performance requirements	18
6.1	General	18
6.2	Performance indication	18
6.3	Elements	19
6.4	Flow control	19
6.5	Waste connections	19
6.6	Product water dispensing outlets	19
6.7	Hazards	20
6.8	Lamp operation indication	20
6.9	Lamp replacement – Systems without UV sensor alarm	20
6.10	Maintenance	20
6.11	Temperature resistance	20
6.12	Corrodible materials	20
6.13	Gaskets, O-rings, shaft seals, and packing materials	20
6.14	Dissimilar metals	20
6.15	Insulating fittings	20
6.16	Plastics	20
6.17	Welding	20
6.18	UV Sensor	21
7	Elective performance claims – Test methods	21
7.1	General	21
7.2	Microbiological performance – Low pressure mercury lamps only	21
7.3	Microbiological performance	30
8	Instructions and information	36
8.1	Installation, operation, and maintenance instructions	36
8.2	Data plate	38
8.3	Replacement components	39
8.4	Performance data sheet	39
	Normative Annex 1 Ultraviolet water treatment systems microbial reduction – MS-2 and T1 procedures	41
N-1.1	Summary	41
N-1.2	Equipment	41
N-1.3	Microorganisms	41

N-1.4	Supplies	41
N-1.5	Reagents	42
N-1.6	Safety precautions and hazards	42
N-1.7	Growth medium	42
N-1.8	Culture of challenge organisms	43
N-1.9	Drinking water treatment unit challenge organism suspension preparation	45
N-1.10	Analysis of influent and effluent samples	45
N-1.11	Challenge verification	46
Normative Annex 2 Ultraviolet water treatment systems microbial reduction – Q β procedures.....		47
N-2.1	Summary	47
N-2.2	Equipment.....	47
N-2.3	Microorganisms	47
N-2.4	Supplies	47
N-2.5	Reagents	47
N-2.6	Growth medium	48
N-2.7	Culture of challenge organisms	49
N-2.8	Drinking water treatment unit challenge organism suspension preparation	51
N-2.9	Analysis of influent and effluent samples	51
N-2.10	Challenge verification	52
Informative Annex 1 Key elements of a certification program for drinking water treatment systems and components		53
I-1.1	Marking the product.....	53
I-1.2	Listing certified companies	53
I-1.3	Annual audits	53
I-1.4	Testing.....	53
I-1.5	Toxicological evaluation of materials formulations	54
I-1.6	Corrective action.....	54
I-1.7	Enforcement	54
I-1.8	Administrative review.....	54
I-1.9	Appeals.....	54
I-1.10	Complaints.....	54
I-1.11	Advertising	55
I-1.12	Records	55
I-1.13	Public notice	55
I-1.14	Confidentiality	55
Informative Annex 2		57
Interpretation Annex.....		59

Foreword²

The purpose of this Standard is to establish minimum requirements for the reduction of microorganisms using ultraviolet (UV) radiation. UV water treatment systems covered by this Standard are intended for water that may be either microbiologically safe or microbiologically unsafe. This Standard also specifies the minimum product literature and labeling information that a manufacturer shall supply to authorized representatives and system owners, as well as the minimum service-related obligations that the manufacturer shall extend to system owners. Systems covered by this Standard are in keeping with the *Report of Task Force on Guide Standard and Protocol for Testing Microbiological Water Purifiers*, April, 1987.³

It is recognized that the federal, state and local objectives are to provide safe water supplies without user treatment. However, many users are faced with the presence of contaminants of both aesthetic and health concern in their water supplies, and need guidance as to the availability of tested and certified point-of-entry (POE) and point-of-use (POU) UV water treatment systems. This Standard will help to meet this need but cannot be expected to address claims beyond those covered in this Standard.

Since it was not economically feasible to mount a routine testing program using all of the target microorganisms, e.g., bacteria, viruses, and protozoan cysts, an equivalent "disinfection" set of tests and requirements was developed for POE and POU UV disinfection systems.

A virus reduction of 4 logs against a poliovirus and rotavirus challenge and a bacteriological reduction of 6 logs against a challenge of a coliform bacteria (*Klebsiella terrigena*) has been recommended by Schaub and an expert task force (1987).³

The technical and health protection problems (laboratory staff) and the inherent cost of establishing and maintaining a live virus test program preclude its routine application in a multipurpose standards testing laboratory. Consequently, an alternate means of assuring virus efficacy was developed.

Survival data for poliovirus and rotavirus (Chang, 1985)⁴ show that between a 3 and 4 log reduction in both poliovirus and rotavirus may be accomplished by a UV dosage of 30,000 $\mu\text{W}\text{-sec}/\text{cm}^2$ while a greater than 6 log reduction of *Escherichia coli* may be projected. Additional data (Harris, 1986)⁵ show a 5 log reduction of poliovirus at 40,000 $\mu\text{W}\text{-sec}/\text{cm}^2$. In NSF/ANSI 55 2000, a minimum UV dosage of 38,000 $\mu\text{W}\text{-sec}/\text{cm}^2$ at the failsafe setpoint was set as an equivalent 4 log virus reduction requirement. To be consistent with International Standards, the minimum UV dose in NSF/ANSI 55 2002 was changed to 40 mJ/cm^2 (40,000 $\mu\text{W}\text{-sec}/\text{cm}^2$) at the alarm set point.

² The information contained in this Foreword is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. Therefore, this Foreword may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

³ *Guide Standard and Protocol for Testing Microbiological Water Purifiers*, Report of Task Force, submitted by Steven A. Schaub to the US EPA, April 1987.

⁴ "UV Inactivation of Pathogenic and Indicator Microorganisms," Chang, J.C., Johnson, J. Doald, et al. *Journal of Applied Environmental Microbiology*, Vol. 49, pp. 1361 to 1365, 1985.

⁵ "UV Inactivation of Selected Bacteria and Viruses With Photoreactivation of the Bacteria," Harris, D. George, Adams, Dean, et al., *Water Resources*, Vol. 21, pp. 687 to 692, 1986.

Prior to the late 1990s, it was thought that UV light had limited cysticidal ability, which required information for the user as to the need for a prefilter complying with NSF/ANSI 53 – *Drinking water treatment units – Health effects* for cyst reduction. Survival data for *Cryptosporidium* (Clancy, 2000)⁶ and *Giardia* (Craig, 2000)⁷ show that a minimum 3 to 4 log reduction in both *Cryptosporidium* and *Giardia* may be accomplished by a UV dosage of 10 mJ/cm².

Where drinking water is considered to be free of disease causing pathogenic organisms and has a turbidity level within acceptable drinking water standards, UV treatment may be useful for the supplemental treatment of this drinking water. It would be suitable for the reduction of normally occurring microbiological flora (nonspore forming heterotrophic bacteria) commonly found in drinking water. Survival data (Chang, 1985)⁴ show that a greater than 2 log reduction of nonspore forming heterotrophic bacteria may be accomplished by an UV dosage of 16,000 μW-sec/cm². The yeast organism *Saccharomyces cerevisiae* was chosen as the test challenge to allow for a reasonable influent concentration and an easily measured reduction in the effluent. Most vegetative bacteria, including coliform species, are too susceptible to UV radiation at the dose range of 16,000 μW-sec/cm² to allow for measurable testing.

This edition of the Standard contains the following revisions:

Issue 49

This revision adds a new protocol under NSF/ANSI 55 to evaluate UV systems across a broader range of wavelengths.

This revision also includes an editorial update to the names of the Annexes within. The Annexes are being changed from alpha characters to numeric, preceded by a 'Normative' or 'Informative'. The table below shows the previous name of the Annex with the corresponding new name of the Annex:

Annexes	
Previously known as:	Now known as:
Annex A	Normative Annex 1 (N-1)
N/A (new)	Normative Annex 2 (N-2)
Annex B	Informative Annex 1 (I-1)
Annex C	Informative Annex 2 (I-2)

This Standard was developed by the NSF Joint Committee on Drinking Water Treatment Units using the consensus process described by the American National Standards Institute.

Suggestions for improvement of this Standard are welcome. This Standard is maintained on a Continuous Maintenance schedule and can be opened for comment at any time. Comments should be sent to Chair, Joint Committee on Drinking Water Treatment Units at standards@nsf.org, or c/o NSF International, Standards Department, PO Box 130140, Ann Arbor, Michigan 48113-0140, USA.

⁶ "Using UV to Inactivate *Cryptosporidium*," Clancy, J. L., et al. *Journal of American Water Works*, Vol 92, Issue 9, pp. 97 to 104, 2000.

⁷ "Inactivation of *Giardia Muris* Cysts Using Medium-Pressure Ultraviolet Radiation in Filtered Drinking water," Craig, S. A., et al. *Water Resources*, Vol. 34, No. 18, pp 4325 to 4332, 2000.

NSF/ANSI Standard for Drinking Water Treatment Units –

Ultraviolet Microbiological Water Treatment Units

1 General

1.1 Purpose

The purpose of this Standard is to establish minimum requirements for the reduction of microorganisms using ultraviolet (UV) radiation. UV water treatment systems covered by this Standard are intended for water that may be either microbiologically safe or microbiologically unsafe. This Standard also specifies the minimum product literature and labeling information that a manufacturer shall supply to authorized representatives and system owners, as well as the minimum service-related obligations that the manufacturer shall extend to system owners.

1.2 Scope

This Standard covers UV microbiological water treatment systems and components for point-of-use (POU) and point-of-entry (POE) applications. This Standard covers systems which use UV radiation within the range of 240 nm to 300 nm inclusive. Systems are intended to be used under the following specific conditions.

1.2.1 Class A systems

Class A POE and POU systems covered by this Standard are designed to be used for treating microbiologically unsafe water, but do not reduce chemical or inert particulate contaminants. Systems covered in this Standard are designed to inactivate microorganisms, including bacteria, viruses, *Cryptosporidium* oocysts, and *Giardia* cysts, from water. Systems covered by this Standard are not intended for the treatment of water that has an obvious contamination or intentional source, such as raw sewage, nor are systems intended to convert wastewater to drinking water. The systems are intended to be installed on visually clear water (not colored, cloudy, or turbid). Systems with manufacturer claims that include components or functions covered under other NSF or NSF/ANSI Standards or Criteria shall conform to the applicable requirements therein.

Class A systems not installed downstream of a device tested for cyst reduction / inactivation in conformance to the appropriate NSF/ANSI Standard may claim *Cryptosporidium* oocysts and *Giardia* cysts only. Class A systems installed downstream of a device tested for cyst reduction in conformance to NSF/ANSI 53 or NSF/ANSI 58 may make a general cyst claim when used on untreated surface waters, or ground water, or both, under the direct influence of surface water.

NOTE — Current data support that *Cryptosporidium* oocysts and *Giardia* cysts are inactivated by UV treatment.

1.2.2 Class B systems or components

Class B POE and POU systems covered by this Standard are designed to be used for supplemental bactericidal treatment for the inactivation of microorganisms that may be present in drinking water (public or private) considered to be microbiologically safe and of known quality. Systems covered under this Standard are intended to inactivate normally occurring nonpathogenic nuisance microorganisms only.